

**Statement of Basis  
Satsop Development Park  
State Waste Discharge  
Permit Modifications**

For clarification, on page 4 of the permit (Effluent Limitations Table), pH 6-9 SU was taken out of the Average Monthly and Average Weekly columns and changed to the following:

Daily minimum is equal to or greater than 6 and the daily maximum is less than or equal to 9.

This permit modification will take out the fecal coliform requirements from page 4 (Effluent Limitations Table) and page 5 (Monitoring Requirements Table) for the following reason:

Depth of water at this site is reported to be approximately 40 feet below land surface. The soils are fairly fined grained (fine sand with clay and silt). The combination of these two parameters should attenuate 1600 cfu/100 ml. Therefore disinfection is not required prior to discharging to the subsurface.